
2009 IFC. 2403.2. Approval Required. Tents and membrane structures having an area in excess of 400 sq. ft. shall not be erected, operated or maintained for any purpose without first obtaining a permit and approval from the fire code official.

Exceptions:

- 1.) Tents used exclusively for recreational camping purposes.
- 2.) Tents open on all sides which comply with the following:
 - a.) Individual tents having a maximum size of 700 sq. ft.
 - b.) The aggregate area of multiple tents placed side by side without a fire break clearance of 12 feet not exceeding 700 sq. ft.
 - c.) A minimum clearance of 12 feet to a structures and other tents.

Number of Tents: _____ Size of Tents: (if multiple tents are used, please specify each tent _____)

Total Square Footage of Tents: _____ Total Number of Occupants: _____

Does the tent meet the above criteria? _____ If, yes, please verify the bottom approved/denied check boxes.

Yes No

Dance Floor: _____ Size of dance floor in sq. ft.: _____

Yes No

Stage: _____ Type of Entertainment: _____

Yes No

Special Effects: _____ Type of Special Effects: _____

Yes No

Cooking under tent: _____ Source of heat: _____

Yes No

Does cooking operation produce grease-laden vapors?

Yes No

Generator to be used: _____ Amount of power: _____ Electrical Inspector: _____
Yes No Approved Denied

Fire Extinguisher(s) present: _____ Type: _____ Mounted correctly: _____
Yes No Yes No

Fire Department Approvals

Prior to beginning any work at the site, your application and floor plans must be approved by Northville Township. Upon approval, you may schedule your inspection. A responsible party must be on site for the inspection. Please be prepared to verify the following items:

Tent Location and Layout:	NFPA 701 Certificate:	Location of Fire Extinguishers:
Approved	Approved	Approved
Denied	Denied	Denied
N/A	N/A	N/A

Exits:	Emergency Lighting:	No smoking signs visible:
Approved	Approved	Approved
Denied	Denied	Denied
N/A	N/A	N/A

FINAL FD APPROVAL:

Approved	Denied	N/A
----------	--------	-----